



Great Geauga County Fair 2010 Electrical, Fire Department Information and must haves!!!!



Fire Department Inspection

- Fire extinguishers are required for *each* site. The minimum rating required is "2A 10BC". Food trailers will need a minimum rating of "2A 20BC". Reminder those of you that had your extinguishers updated at the 2009 GGCF those will be expired inspection status the week prior to arrival.
- **Any and all deep frying trailers must have a "K Type" extinguisher.**
- **The Burton Fire Inspectors will be inspecting Thursday all units, please ensure that an owner or knowledgeable representative of the owner is present on the grounds Thursday to answer any and all questions of the inspection teams**
- All extension cords must be grounded (3 wire at least 14 gauge. All cords must be UL approved and suitable for intended use. Power strips must have at least a 15 amp breaker. NO GREEN 2 WIRE 18 GAUGE EXTENSION CORDS WILL BE ALLOWED IN ANY BOOTH OR STAND
- All general lighting in tents and public areas *must* have construction covers/cages and be UL approved. Periodic inspections will be made by the electrician.
- All outdoor electrical connections *must* have a GFI receptacle. This will be strictly enforced.
- Tents must be GFI protected—either at the pole or at the tent. The only exception to this would be refrigerators/freezers; however, they must be OFF the ground.
- All cords must be tagged with the appropriate tag (provided by the concessions office) or they will be disconnected.

**THANK YOU FOR YOUR COOPERATION IN
ADHERING TO THESE FIRE REGULATIONS!**

Electrical Information

Inside spaces are wired to accept a regular 110 volt plug for any lights or electrical devices you may need. Outdoor concessions should consider proper lighting (MUST BE GFI protected and have light covers) of your outside booth for night use. Electricians will be on hand to hook up concessions needing electric on a first come, first serve basis. They will be available during our office hours. Should you have any electrical difficulties, please alert the concessions office. Romex wire cannot be used for any reason on the fairgrounds. Tampering with electrical equipment will not be tolerated--Concessionaires will be held responsible for any damages. Should you have any electrical difficulties, please alert the concessions office.

Electrical Tags

All outdoor concessions will be required to mark their cords with an electrical tag provided to you by the concessions office. The tag is merely designed to identify the concession and amps of electricity being drawn. The tag should remain attached to the cord for the duration of the fair. Tags will also be furnished for stock trucks and campers which require and have paid for electrical hook up.